



ZHEJIANG YONGHE REFRIGERANT CO., LTD.

Certificate of Analysis

Product: HFC-134A

Batch No.: A220305CK

Standard: GB/T18826-2016

The date of report: May 6th, 2022

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	% ($\geq$)	99.90	99.94
Moisture	% ($\leq$)	0.0001	0.0009
Acidity	(as HCL) %	0.0001	<0.0001
Vapor Residue	% ($\leq$)	0.005	<0.005
Non condensable gas	% ($\leq$)	1.5	0.8
Conclusion	Qualified		
Remark	TJBA041/YH2209		

Inspector: Xu Jianfu

Review: Liu Wangxing

Check: Ke Xuemei