



ZHEJIANG YONGHE REFRIGERANT CO., LTD.

Certificate of Analysis

Product: R404A

Batch No.: WH210516/WH210517

Standard: Q/ZYH 005-2019

The date of report: Jan. 9th, 2022

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	% ($\geq$)	99.90	99.93
Moisture	% ($\leq$)	0.0010	0.0009
Acidity	(as HCL) %	0.0001	<0.0001
Vapor Residue	% ($\leq$)	0.010	<0.01
Non condensable gas	% ($\leq$)	1.5	1.0
Conclusion	Qualified		
Remark	TJBA041/YH2201		

Inspector: Wang Jianfu Review: Liu Wangxing Check: Ke xuemei

浙江永和制冷股份有限公司
ZHEJIANG YONGHE REFRIGERANT CO., LTD.