



ZHEJIANG YONGHE REFRIGERANT CO., LTD.

Certificate of Analysis

Product: R507A

Batch No.: WH211023/YH211024

Standard: Q/ZYH012-2019

The date of report: Jan. 10th, 2022

Items	Unit	Index	Inspection Results
Odor		No strange stench	Qualified
Appearance		Colorless and no turbid	Qualified
Purity	% ($\geq$)	99.90	99.92
Moisture	% ($\leq$)	0.0010	0.0009
Acidity	(as HCL) %	≤ 0.0001	< 0.0001
Vapor Residue	% ($\leq$)	0.010	< 0.010
Non condensable gases	% ($\leq$)	1.5	0.9
Conclusion	Qualified		
Remark	TJBA041/YH2202		

Inspector: Wang Jianfu Review: Liu Wangxing Check: Ke xuemei

浙江永和制冷股份有限公司

ZHEJIANG YONGHE REFRIGERANT CO., LTD.